


CERTIFICATE

Certificate holder	TECE GmbH Hollefeldstr. 57 48282 Emsdetten GERMANY
Product	Plastic piping systems for warm water floor heating systems and radiator connecting
Type, Model	TECE floor/SLQ MVR (M)
Testing basis	DIN 4726:2008-10 DIN EN ISO 21003-2:2011-07 DIN EN ISO 21003-3:2008-11 DIN EN ISO 21003-5:2008-11 Certification scheme plastic piping systems for warm water floor heating systems and radiator connecting (2015-01)
Mark of conformity	
Registration No.	3V377 MVR (M)
Valid until	2019-04-30
Right of use	This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number. See annex for further information.

ANNEX

Certificate 3V377 MVR (M) dated 2015-09-29

Technical Data

Pipe:

- Production plant: Multilayer Pipe Company, Strzelin
- Material designation: MVR
- Nominal-outside diameter x nominal thickness (mm): 16 x 2
- Design class: C
- Application class and operating pressure:
Class 4/ 6 bar

Fitting/Connector:

- Name of the manufacturer: Simplex Armaturen
- Type of fitting: Push fitting, clamp fitting
- Material designation: metal
- Type designation: Simplex

- Name of the manufacturer: TECE GmbH & Co. KG
- Type of fitting: Plug-in connector
- Material designation: PPSU
- Type designation: TECElogo

- Name of the manufacturer: TECE GmbH & Co. KG
- Type of fitting: Sliding sleeve fitting
- Material designation: PPSU
- Type designation: TECEflex

**Testing laboratory/
Inspection body**

IMA Materialforschung und
Anwendungstechnik GmbH
Postfach 80 01 44
01101 Dresden
GERMANY

Test report(s) B044/14 dated 2014-04-01
B755/14 dated 2015-06-03

